

CHRISTY B16 BOX AND  
FL16D NON-CONCRETE LID  
OR APPROVED EQUAL

8" MAX. (FROM ANGLE CURB  
STOP TO BOTTOM OF LID)

3" MAX. (FROM ANGLE CURB  
STOP TO INSIDE BOX WALL)

CITY  
RESP.  
PROPERTY OWNER  
RESP.



30° MIN.  
COVER

BRONZE DOUBLE STRAP  
SERVICE CLAMP

1" ANGLE CURB STOP,

FORD KV43-444WNL  
OR APPROVED EQUAL

1 1/2" AND 2" ANGLE CURB STOP, FORD

FV43-666W-NL OR FV43-777W-NL OR APPROVED  
EQUAL

ONE CONTINUOUS ADS PBLE WATER  
SERVICE TUBING (CTS PEAT710 OR  
APPROVED EQUAL

CORPORATION STOP WITH CC THREADS  
FORD FB100-4-NL (1"), FB1100-  
67-NL (1 1/2), FB 1100-7-NL (2")  
OR APPROVED EQUAL

BACKFILL WITH SAND FROM MAIN TO CURB STOP

**NOTES:**

1. FOR 1" WATER SERVICE USE CHRISTY B-16 UTILITY BOX WITH FL16D NON-CONCRETE LID OR APPROVED EQUAL (AS SHOWNED), FOR 1 1/2" AND 2" WATER METERS, USE CHRISTY B-36 UTILITY BOX WITH FL36D NON-CONCRETE LID OR APPROVED EQUAL



City of Greenfield  
Public Works Department

Approved by *[Signature]* 1/17 Date 12/19 Revised

**TYPICAL 3/4" THRU 2"  
WATER SERVICE  
INSTALLATION**

DRAWING  
NO.

W-1